

harry gage - buyer
E.I. DuPont. owner

TRANSYLVANIA COUNTY HEALTH DEPARTMENT

(Sewage disposal system) Improvements Permit and Certificate of Completion

(Ground Absorption Sewage Disposal System - Section 130 - 160 of Chapter 130 of the General Statutes of North Carolina)

OWNER-OCCUPANT "SPEC" BUILDING CONTRACTOR BOB COLWELL
LOCATION KINGFISHER RD END OF RD @ CURVE SAC
SUBDIVISION WLAHEE HILLS TL LOT NO. 312 SECT. OR BLOCK NO. _____
SEPTIC TANK CONTRACTOR HAROLD Houck ADDRESS BREVAIRD

HOUSE MOBILE HOME BUSINESS
NO. BEDROOMS 3 NO. BATHROOMS 2
SIZE OF SEPTIC TANK 800 GALS. (Liquid) _____
MATERIAL: PRE-CAST BLOCK FIBERGLASS
DISTRIBUTION BOX YES NO
NO. OF LINES 3 WIDTH 6 FT. LENGTH 100 FT.
PERCOLATION TEST YES NO
WATER SUPPLY: INDIVIDUAL PUBLIC
SITE CLASSIFICATION: SUITABLE CLAY
PROV. SUITABLE ≡
UNSUITABLE

IMPROVEMENTS PERMIT: DATE: _____
BY: _____
CERTIFICATE OF COMPLETION: DATE: 1-19-79
BY: _____

NOTICE: System installed according to Rules and Regulations but not a guarantee that it will function satisfactorily for any given period of time.

COLOR CODE: White - Owner; Pink - Improvements Permit; Blue - Contractor; Yellow - Inspection Dept.; Green - Health Dept.

