

**CERTIFICATE OF COMPLETION**

**MADISON COUNTY HEALTH DEPARTMENT**

Property Owner: Wayne Alvey File: 8756 Phone: 689-0016 / 689-8112  
 Property Address: Bull Creek Rd. Marshall Date: 5-15-00

140 Health Care Lane  
 Marshall, NC 28753  
 704-649-3531

Location: Bull Creek to end (Rt) at fork (L) Behind S.W. to site on (Rt)  
 Subdivision: \_\_\_\_\_ Section: \_\_\_\_\_ Lot Number: \_\_\_\_\_

Water Supply: Well

New Septic Tank System  Tank Material: Concrete  Other  Manufacturer: Aracma (Existing) Liquid Capacity: 1000 gals

Built In Place Tank: Material \_\_\_\_\_ Inside Dimensions: Length \_\_\_\_\_ Width \_\_\_\_\_ Liquid Depth \_\_\_\_\_ Liquid Capacity \_\_\_\_\_

Nitrification Field: Square Footage 1080 Lines 3 Length 120' Width 3' Depth of Gravel 0-

Other Type Disposal: Polystyrene aggregate (E-2 lay) system

Repair To Existing System  Existing Tank: Yes  No  Material: Concrete  Block  Other  New Tank  Gal. Liquid Capacity \_\_\_\_\_

Nit. Field: Existing Square Footage \_\_\_\_\_ Square Footage Added \_\_\_\_\_ Total Sq. Footage \_\_\_\_\_ No. Lines \_\_\_\_\_ Length \_\_\_\_\_ Width \_\_\_\_\_

**SYSTEM DESIGNED FOR:**

Residence  Bedrooms 4 Mobile Home  Bedrooms \_\_\_\_\_ Other Establishment  Type \_\_\_\_\_

Basement: Yes  No

Nearest Distance To Water Supply ≠ 50' Stream ≠ 50' Foundation ≠ 15' Property Line ≠ 10' Installed By: Bo Burnett

Remarks: No plowing over system area.

Approved: Yes  No  Sanitarian Jamie Fox RS Notice: This approval is issued subject to all the provisions of Rules and Regulations governing the design, installation, cleaning and use of sewage disposal systems in Madison County, Section 1900 of the North Carolina Administrative Code, and Chapter 130, Article 13E of the General Statutes of North Carolina. **No person is permitted to make alterations in the design or use of this system other than its designated use without approval of an authorized sanitarian. This approval indicates that this system has been installed in compliance with the standards as set forth in the above regulations, but shall in no way be taken as a guarantee that the system will function satisfactorily for any given period of time.**

