

Permit #: 03-489
 Agent/Owner: CHASEWOOD CONSERVATION LLC
 Mailing Address: 30 Camptown Rd. Brevard, NC
 Work Phone #: ()
 Mailing Address: 8574-62-1916-000

Home Phone #: () Greg Nelson 894-2937
 Proposed Buyer: New owner: William Rowland
 Home Phone #: ()
 Work Phone #: 810 Hendry St. Glenwood, NC
 Property Location: Island Ford (847) 789-8644
 Subdivision: Chasewood
 Phase/Sec: Lot #: 30

Directions to property: COUNTRY CLUB TO INTERSECTION WITH ISLAND FORD TURN RIGHT PROP ON RIGHT

Flood Zone	
Is the property in a flood zone?	
<input type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> Unknown
Inspections	
Flood Zone	Inspections
<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Approved <input type="checkbox"/> Disapproved
Initials	Date

Installation for: Mobile Home Single Double House No. Bedrooms: 3
 Basement: Yes No With/Plumbing: Yes No Ind./Commercial Other

If Industry/Commercial/Other: _____ Number of employees: _____ Operation: (Describe) _____
 Lot size: 1.44 Date lot recorded: _____ Right of ways, easements, etc. _____
 Property contains designated wet lands: Yes No

Water Supply: Private Spring Well Shared Supply Public/Community

I certify the above to be correct to the best of my knowledge. Permission is hereby granted to perform a site/soil evaluation on the property described above. If the information submitted in this application is falsified or changed, the permit shall become void. I understand that it is my responsibility as the applicant/agent/owner to comply with all applicable ordinances, laws, and rules from other agencies that may affect the development of this property.
 Applicant/Agent Signature: Greg Nelson Date: 9-26-03

IMPROVEMENT PERMIT
PERMIT EXPIRES: 12/4/08

This on-site wastewater treatment and disposal system improvement permit is issued in accordance with Article 11 of Chapter 130A of the General Statutes of North Carolina and the rules adopted pursuant to this Article. This improvement permit is issued for the property and is to serve the facility as described in the application above. The improvement permit must be accompanied by an "Authorization for Wastewater System Construction" prior to the installation or repair of the wastewater system or before any required building permits can be issued. This improvement permit is transferable provided that both the site for the wastewater system and the facility the system serves are unchanged and remain under the ownership or control of the person owning the facility.

Wastewater System Design Flow: 360 GPD Proposed On-Site Wastewater Disposal System: conventional (gravel) Long Term Application Rate: 5 Max. Trench Depth: 24 in.
 Comments and special conditions: _____

Issued by: Alan Smith MS, RS Date: 12/4/03 Issued to: John K Date: 12/8/03

ANY ALTERATIONS OR MODIFICATIONS (MAN MADE OR NATURAL) TO THE SITE, SYSTEM DESIGN FLOW, OR CONDITIONS IN WHICH THE PERMIT WAS ISSUED WILL VOID THE PERMIT.

Agent/Owner: CHASEWOOD CONSERVATION LLC
 Mailing Address: 30 CANTOWN RD. BREVARD, NC

Home Phone #: () Greg Nelson 884-2937
 Work Phone #: ()

Proposed Buyer: New owner: William Burchard
 Mailing Address: 3000 Henley St. Glenwood, NC

Home Phone #: ()
 Property Location: Island Ford (847) 789-8664
 Subdivision: Chasewood
 Phase/Sect.: 6035
 Lot #: 30

Directions to property: COUNTRY CLUB TO INTERSECTION WITH ISLAND FORD TURN RIGHT PROP ON RIGHT

Is the property in a flood zone? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown	
Flood Zone Inspections	
<input type="checkbox"/> Flood Zone	<input type="checkbox"/> Yes <input type="checkbox"/> No
<input type="checkbox"/> Approved	<input type="checkbox"/> Disapproved
Initials _____	Date _____

Installation for: Mobile Home Single Double House No. Bedrooms: 3 Basement: Yes No With Plumbing: Yes No Int'l/Commercial Other

If Indust./Commercial/Other: _____ Number of employees: _____ Operation: (Describe) _____ Property contains designated wet lands: Yes No

Lot size: 1.44 Date lot recorded: _____ Right of ways, easements, etc. _____ Water Supply: Private: Spring Well Shared Supply Public/Community

I certify the above to be correct to the best of my knowledge. Permission is hereby granted to perform a site/soil evaluation on the property described above. If the information submitted in this application is falsified or changed, the permit shall become void. I understand that it is my responsibility as the applicant/agent/owner to comply with all applicable ordinances, laws, and rules from other agencies that may affect the development of this property.

Applicant/Agent Signature: [Signature] Date: 9-26-03

**AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION
 (Diagram and Conditions Attached)**

New Installation: Repair/Addition: Original Permittee: _____ Dated: _____

Design waste flow: 3600 GPD LTRAR: 5 Septic Tank Capacity: 1000 gal./min. Pump Tank Capacity: _____ gal./min. Proposed Wastewater System: conventional gravel

Drainfield: Total Trench Length: 240 ft. Square Footage: 720 Trench spacing: 9 ft. on ctr. Individual Trench Length: 80 ft. Maximum Trench Depth (Low Side): 24 in. Trench Width: 36 in.

Distribution Method: D-box Min. distance between system and nearest Well: 160 ft. Water line: 10 ft. Foundation: 15 ft. Property line: 10 ft. Vertical Cut: 15 ft.

Comments & Special Conditions: _____

Construction of the wastewater system for the permit indicated is hereby authorized. The wastewater system described in the improvement permit has been designed and can be installed and operated in compliance with Article 11 of Chapter 130A of the General Statutes of North Carolina and Rules adopted pursuant to this Article. This Construction Authorization is valid for a period of 5 years from the original date of issue. The Construction Authorization must be renewed upon expiration prior to the installation/repair of the wastewater system, or prior to the issuance of any required building permits. A pre-construction conference with the owner or developer, or an agent of the owner or developer, and the health department will be required for re-issuance of the Construction Authorization.

I agree to install the wastewater disposal system in accordance with the improvement permit, construction authorization and any conditions specified therein.

Signed: [Signature] Date: 12/4/03 Construction Authorization prepared by: [Signature] Date: 12/4/03

PERMIT AND CONSTRUCTION AUTHORIZATION MUST BE ON SITE DURING ALL PHASES OF CONSTRUCTION/INSTALLATION AND INSPECTION

Permit No.: 03-489

house was not staked out at the time of the septic evaluation; therefore, the location is approximate; the house is not drawn to scale

NOT For Installation or Building Construction

Repair Area
Type IIa

Notice:
Well must be located at least 100 ft. from any part of the septic system.

15' S.T.

80' 80' 80'

Repair Area

HOUSE (NTS)

proposed drive/
parking

Nottingham Drive

Cambridge Drive

N
per plat

N 31°31'32" E 271.15'

N 17°45'32" W 203.54' (27)

S 74°55'27" W 178.67'

NOT For Installation or Building Construction

