

**HENDERSON COUNTY HEALTH DEPARTMENT  
OPERATIONS PERMIT**

**OP No. 1688**

Owner Janice Busche & Jim Devermond Date 10/21/96

Building Contractor \_\_\_\_\_

Septic Tank Installer Regan Youngblood

Lot No. \_\_\_\_\_ Development \_\_\_\_\_

Location 191 T/L 280 to (R) on drive at Turkey  
Pen. Rd (just before Co. Line)

House  Mobile Home

Other \_\_\_\_\_

No. Bedrooms 2 Design Flow GPD 240

Lot Size \_\_\_\_\_

Owner's Signature Jim Devermond

**VALID ONLY FOR USE AS DESCRIBED ABOVE  
DRAWING NOT TO SCALE**

AC No. 643

I.No. 38027

WI No. 3583

Water Supply:  Community  Shared  
 Individual  City

Tank Size 13-1000 Gal. 9/27/96

Drainfield 600 equiv Sq. Ft. JRR

Stone Depth N/A Inches

System Type E LDP (with Strallow)

Min. System Review Frequency 5

Issued By: Vicki Gomez  
Environmental Health Specialist

*DAVIS*

Tank checked by JRR 9/27/96

Field checked by VE 10/15/96

Final cover checked by Vicki 10/21/96

