

# Transylvania County Health Department Certificate Of Approval

8592-95-8097-000

The sewerage disposal system described on the record below has been inspected and approved by an agent of the Transylvania County Health Department.

New House  
Sherwood Forest, Inc. - Builder or L. S. McEwen, R.S. Signed

## Sewage Disposal Record

Occupant Lot D11 Owner Mr. & Mrs. Francis  
 Location of Building Sherwood Forest Development  
 Address 41 E. Brevard, N.C.  
 Contractor Harold Houck Address Brevard, N.C.  
 Date of Inspection 8-15-72 No. of Bedrooms 3 Baths 2 No. of Users \_\_\_\_\_

Septic Tank Materials: Concrete Block (Size \_\_\_\_\_ in.)  Poured Concrete  Pre-Cast

Capacity 900 Gals. Single or Double Compartment

Adequate For: Garbage Grinder    
 Yes No

Nitrification Field Materials: Terra Cotta  Concrete  Perforated Plastic

Distribution Box Yes No. of Lines 2 Width 4 ft. (each) Length of Lines 75 ft. (each)  
 Stone ✓ Other \_\_\_\_\_

Adequate For: Washing Machine    
 Yes No

Sand Filter No. of Lines \_\_\_\_\_ Width of Line \_\_\_\_\_ Length of Line \_\_\_\_\_ Approved Sand \_\_\_\_\_

Precolation Test   Note: Community water system.  
 Yes No

Sketch of System

