

# Transylvania County Health Department Certificate of Completion

The sewage disposal system described on the record below has been inspected and approved by an agent of the Transylvania County Health Department.

Proposed Name

Harold C. McDowell

Signed

## Sewage Disposal Record

Occupant \_\_\_\_\_ Owner Jack Bryant

Location of Building sect 1 lot #4 Knob Creek Dev.

Address Rt 1 Pugh Forest

Contractor Allison Ditching Ser. Address Horse Shoe

Date of Inspection 7-15-74 No. of Bedrooms 4 Baths 3 No. of Users \_\_\_\_\_

Septic Tank Materials: Concrete Block (Size \_\_\_\_\_ in.)  Poured Concrete  Pre-Cast

LARGE TANK

Capacity ~~1100~~ 1100 Gals. Single or ~~Double~~ Compartment

Adequate For: Garbage Grinder    
Yes No

Nitrification Field Materials: Terra Cotta  Concrete  Perforated Plastic

Distribution Box YES No. of Lines 2 Width 8 FT wide Length of Lines 100 FT  
Bed

Stone  Other \_\_\_\_\_

Adequate For: Washing Machine    
Yes No

Sand Filter No. of Lines \_\_\_\_\_ Width of Line \_\_\_\_\_ Length of Line \_\_\_\_\_ Approved Sand \_\_\_\_\_

Precolation Test    
Yes No

Sketch of System

