Case Number: SEP 2021-06891

BUNCOMBE COUNTY HEALTH CENTER

Oppermit.doc.rev 01/16

PIN: 9720808684

ENVIRONMENTAL HEALTH SERVICES (828-250-5016)

OPERATIONS PERMIT

Property Owner: 158 Coleman LLC Property Location: Nelva Rd. Application Date: 41/30/2
Directions: Gurnan Bridge to Nela Rs. Second on Risht
Subdivision: Phase/section: Lot# Installer: Bort left Construction Cert. # 4988-
Water Supply: □ Private Well □ Shared Well ★ Community/Public □ Spring Min. Required Separation Distance / UU Installed? □ Yes → No
Conditions: 1) Pump septic tank every 3 to 5 years. 2) Clean septic tank effluent filter annually or as needed. 3) Divert all gutters and other surface water, away from septic system and repair areas. 4) No cutting or filling over septic system and repair areas.
Representation of the state of
Operations Permit For: New System Repair Revision Drawings, plans, conditions, etc. attached? Yes No System Approved For: House Mobile (single double) Bedrooms:
Business: No. of Employees:Number of Shifts: Industrial Waste: \(\Bar{\text{Yes}} \) No Type: Operation Maintenance & Monitoring Description (if applicable):
Approved Installation Specifications: Total Design Flow: 240 LTAR: 44 System Classification: Type I, II, *III_£, IV, *V, *VI
Septic Tank Capacity: 1000 Date of Tank Manuf.: The Tank Serial Number: Septic Tank Location: GPS Latitude: 35 37 19 (Gallons) Longitude: 82 36 18 W
Pump Specification: Pump Make: Model: Serial No.: Serial No.:
System Type Installed:
*-Type IIIb pump systems to be inspected every 5 years; *-Type V & VI expire in 5 years
Inspected by: 9 A With Date: 3/30/22 Issued To: Limanhi Date: 3/30/27
The system has been installed in compliance with the applicable NC General Statutes, Rules for Sewage Treatment and Disposal. Approval does not guarantee the system will function satisfactory for any given time. Oppermit.doc.rev 01/16